

Olsson Associates
Consulting Engineers
1111 Lincoln Mall
Lincoln, Nebraska
October 9, 2006

ADDENDUM NO. 1

Repainting Pedestrian Bridges
27th & Highway N-2 for
Lincoln Parks & Recreation
City Spec. No. 06-288
OA Project No. 2006-0509

TO ALL WHO HAVE RECEIVED PLANS AND SPECIFICATIONS FOR THE REFERENCED PROJECT.

1. Refer to Specification Section 09900 – Part A: SURFACE PREPARATION AND PAINTING

- a. Delete the first sentence of Paragraph 1.01 B in its entirety and replace with the following.
“The Contractor or its subcontractor(s) shall furnish all labor, materials, equipment, services, and incidentals necessary to clean and paint each of the truss or fence structures indicated in the plans.”
- b. Add the following work covered by this section and included in the bid item “Painting Bridge No. _____” to paragraph 1.01 C.
“Fill all holes used to attach the existing fencing with Lab-metal filler compound by Alvin Products or approved equal. After filling the holes with the filler compound, sand or grind to a feather edge.”

2. Refer to Plan Sheet 3, Fence Fabric Details (Bridge No. 1 & No. 3)

- a. Delete all references to ‘2”x2”x0.159” Dia. Galv. Wire Mesh Fence’ and replace with ‘Galvanized WWR 4x2-W2xW2 Wire Mesh Fence.’
- b. Add Note No. 8 to the Fence Fabric Notes: “Wire mesh fence shall be installed with 4” opening dimension in vertical direction.”
- c. The Welded Wire Reinforcing (WWR) can be obtained in sheet sizes equal to a panel size. Therefore, delete details “B” and “G.”

3. Refer to Plan Sheet 4, Fence Fabric Details (Bridge No. 2)

- a. Delete all references to ‘2”x2”x0.159” Dia. Galv. Wire Mesh Fence’ and replace with ‘Galvanized WWR 4x2-W2xW2 Wire Mesh Fence.’
- b. Add Note No. 8 to the Fence Fabric Notes: “Wire mesh fence shall be installed with 4” opening dimension in vertical direction.”
- c. The Welded Wire Reinforcing (WWR) can be obtained in sheet sizes equal to a panel size. Therefore, delete details “B” and “H.”

4. Refer to Plan Sheet 5, Fence Fabric Details (Tower Fencing)

- a. Delete all references to '2"x2"x0.159" Dia. Galv. Wire Mesh Fence' and replace with 'Galvanized WWR 4x2-W2xW2 Wire Mesh Fence.'
- b. Add Note No. 8 to the Fence Fabric Notes: "Wire mesh fence shall be installed with 4" opening dimension in vertical direction."
- c. The Welded Wire Reinforcing (WWR) can be obtained in sheet sizes equal to a panel size. Therefore, delete details "B" and "G."

Each Bidder must acknowledge receipt of all addenda in the space provided on the Proposal Form.

